सत्यमेव जयते

GOVT. OF ASSAM

OFFICE OF THE DIRECTOR

FIRE AND EMERGENCY SERVICES, ASSAM

PANBAZAR, GUWAHATI

Form - G

UBIN : **301/72353/NOPAN/6/2024**

UAIN : **FNESBNOCI/2024/01701**

NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN APPLICATION FOR FIRE NOC FOR ONE STORIED / MULTI-STORIED / HIGH RISE BUILDING UNDER ASSAM FIRE SERVICE RULE 1989 (FORM NO I)

Hazard Category: **Low Hazard**

This NOC is issued to **Roushan National School** on **22/07/2024** with reference to Compliance Report No. **NIL** dated **13/07/2024**

I here by certify that the building as per description below at **Dag N o . 625,631,632,629,623,624,630 Patta No. 178,179,34 Mouza Bhairabpad Place Gotlong Dolabari, SONITPUR** has been inspected in respect of implementation of inbuilt Fire Fighting,Fire Prevention and Means of escape measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has no objection in its occupation/ utilization for the purpose of:

DETAILS OF APPROVED OCCUPATION

S. No.	Floor	Floor Area	Purpose of Utilization
1.	GROUND FLOOR	3000 SQM	SCHOOL

THIS NOC IS VALID UP TO **22/7/2027**

Place of issue : **GUWAHATI**

Date of issue : **22/07/2024**

Director of Fire and Emergency Services,
Guwahati, Assam

(Subject to Conditions mentioned here under)

CONDITIONS :

1. There should not be any change of Trade for which this License has been issued.
2. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
3. The fire fighting equipments should be in serviceable condition at all time
4. Water reservoir should always be kept full up to brim
5. The entrance and exit and the water reservoir should always be free from any obstruction/projection.

President
Roushan National School
(Under the aegis of Roushan Foundation)